

TITLE 267 – NEBRASKA OIL AND GAS CONSERVATION COMMISSION

CHAPTER 3 – DRILLING, DEVELOPMENT, PRODUCING AND ABANDONMENT

024 LEASE TANK RESERVOIRS AND FIRE HAZARDS

All oil storage and lease tanks must be surrounded by an earthen dike which shall provide a capacity of one and one-tenth (1-1/10) times the capacity of the largest tank it surrounds.

All well and tank locations shall be kept free of dead grass, brush, weeds and other inflammable material and so maintained at all times.

